

Annual Drinking Water Quality Report
Tolna, North Dakota - ND3200944
2016

The City of Tolna, as required by the federal Safe Drinking Water Act, has prepared this year's annual drinking water quality report. This report is designed to inform you about the safe clean water we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. The City of Tolna purchases its water from the Greater Ramsey Water District. Greater Ramsey Water District's water source is entirely groundwater. Water is obtained from the Spiritwood Aquifer, drawn from 3 production wells located in Nelson County. Greater Ramsey Water District's treatment plant uses a process to remove iron and manganese from the water. Prior to leaving the plant, chlorine for disinfection, fluoride to help prevent tooth decay, and a chemical to help prevent problems associated with lead and copper plumbing located in older homes, is added.

Source Water Assessment

Our public water system, in cooperation with the North Dakota Department of Health, has completed the delineation and contaminant/land use inventory elements of the North Dakota Source Water Protection Program. Based on the information from these elements, the North Dakota Department of Health has determined that our source water is not likely susceptible to potential contaminants. Information from the wellhead protection report is available for review at our office during normal business hours. Arrangements can be made at our business office to obtain a copy of the report.

Contaminants Which May Reasonably Be Expected to Be Found in Drinking Water and Bottled Water:

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water:

***Microbial Contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

***Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

***Pesticides and Herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

***Organic Chemical Contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

***Radioactive Contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Tolna routinely monitors for contaminants in your drinking water according to Federal and State laws. The following tables show the results of our monitoring for the period of January 1st to December 31st, 2016. As authorized and approved by EPA, the state has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of our data [e.g., for radioactive contaminants], though representative, is more than one year old.

Table of Detected Regulated Contaminants

(The data presented is for 2011-2015 or the most recent in accordance with state and federal regulations.)

AL = Action Level

MCL = Maximum Contaminant Level

MCLG = Maximum Contaminant Level Goal

MRDLG = Maximum Residual Disinfectant Level Goal

MRDL = Maximum Residual Disinfectant Level

n/a = Not applicable

nd = None detected

pCi/l = picocuries per liter (a measure of radioactivity)

ppm = parts per million, or milligrams per liter

TT = treatment technique

Highest Compliance Level = The highest level of that contaminant used to determine compliance with a National Primacy Drinking Water Regulation.

Range of Detections- The lowest to the highest result value recorded during the required monitoring timeframe
for
Systems with multiple entry points.

Disinfectants= Chlorine CITY OF TOLNA

		MCLG	High Comp	Units	Range
3/31/16		MRDL=4.0	1.7	ppm	1.22 to 1.59

Lead/Copper CITY OF TOLNA

	<u>Violation Yes/No</u>	<u>Date</u>	<u>#Samples</u>	<u>Action Level (AL)</u>	<u>90th Percentile</u>	<u>Samples Exceed AL</u>	<u>Units</u>	<u>Likely Source of Contamination</u>
Copper 90 th Percentile	No	8-19-16	5	1.3	.501	0	ppm	Corrosion of household plumbing systems, erosion of natural deposits, leaching from wood preservatives.
Lead 90 th Percentile	No	8-19-16	5	15	.56	0	ppb	Corrosion of household plumbing systems, erosion of natural deposits

Stage 2 Disinfection Byproducts (TTHM /HAA5) GREATER RAMSEY WATER DISTRICT

	<u>System/Site</u>	<u>Date</u>	<u>MCL</u>	<u>MCLG</u>	<u>High Comp</u>	<u>Units</u>	<u>Range</u>
HAA5	System-Wide	12/31/16	60		No detect	ppb	N/A
TTHM	System-Wide	12/31/16	80		1	ppb	N/A

Radioactive Contaminants GREATER RAMSEY WATER DISTRICT

	<u>Violations Yes/No</u>	<u>Date</u>	<u>MCLG</u>	<u>MCL</u>	<u>Highest compliance level</u>	<u>Unit of Measurement</u>	<u>Range of Detections</u>	<u>Likely source of contamination</u>
Gross Alpha, including RA, excluding RN & U	No	8/3/15	15	15	.08	pCi/l	n/a	Erosion of natural deposits
Radium, combined (226,228)	No	8/3/15	5		.56	pCi/l	n/a	Erosion of natural deposits
Uranium, combined	No	8/3/15	30		.66	ppb	n/a	Erosion of natural deposits

Inorganic Contaminants CITY OF DEVILS LAKE

	Violation Yes/No	Date	MCLG	MCL	Highest Compliance Level	Unit of Measurement	Range of Detections	Likely Source of Contamination
Arsenic	No	2/23/15	0	10	4.89	ppb	n/a	Erosion of natural deposits; runoff from orchards; runoff from galss and electronics production wastes.
Barium	No	5/21/14	2	2	.052	ppm	n/a	Discharge of drilling waster; discharge from metal refineries; erosion of natural deposits
Chromium	No	5/21/14	100	100	1.71	ppb	n/a	Discharge from steel and pulp mills; erosion of natural deposits
Flouride	No	5/21/14	4	4	.77	ppm	n/a	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate-Nitrite	No	2/24/16	10	10	1.12	ppm	n/a	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits

Radioactive Contaminants CITY OF DEVILS LAKE

	Violation Yes/No	Date	MCLG	MCL	Highest Compliance Level	Unit of Measurement	Range of Detections	Likely source of contamination
Gross Alpha, including RA & U	No	4/11/11	15	15	.9	PCi/l	n/a	Erosion of natural deposits
Radium, combined (226,228)	No	4/11/11		5	.83	pCi/l	n/a	Erosion of natural deposits
Uranium, combined	No	4/11/11		30	.11	ppb	n/a	Erosion of natural deposits

Stage 2 Disinfection Byproducts (TTHM/HAA5)

	System/Site	Date	MCL	MCLG	High Comp	Units	Range
HAA5	System Wide	12/31/16	60		14	ppb	n/a
TTHM	System Wide	12/31/16	80		34	ppb	n/a

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Greater Ramsey Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. **Use water from the cold tap for drinking and cooking. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.** If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

++As you can see by the table, results from testing our water that our drinking water meets or exceeds all Federal and State requirements. We have learned through monitoring and testing that some contaminants have been detected. The EPA has determined that our water is safe at these levels.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Total Coliform: The Total Coliform Rule requires water systems to meet a stricter limit for coliform bacteria. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public by newspaper, television or radio. To comply with the stricter regulation, we may need to increase the average amount of chlorine in the distribution system. Please call Vicky Engen, Tolna City Auditor, at (701) 262-4749 if you have questions concerning your water system.

The City of Tolna works diligently to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life, and our children's future.

Mayor
Steve Dahl

Tolna Council Members

Bret Poehls
Jeremy Weber
Kayln Luehring

City Auditor
Vicky Engen

Tolna Public Works Superintendent
Dennis Johnson

